



Lightning Protection for Communications Facilities

Radio and TV broadcast towers are often the tallest objects around and as such are especially susceptible to damage from lightning (not to mention other natural phenomenon). A session at the upcoming NAB Broadcast Engineering Conference (BEC, April 9-14, 2011, Las Vegas, NV – see below for additional information) entitled “*Emergency Operations – Planning and Implementation*” includes a paper, excerpted here, which focuses on reviewing several case histories involving lightning damage, and highlighting the power quality infrastructure that may be adapted to benefit any facility that operates electronic equipment. This paper is entitled “*Case Histories in Lightning Protection – Communications Facilities,*” and was written by David Brender, P.E., Copper Development Association, Inc.

WHY GROUND? – one of the primary purposes of grounding electrical systems is to provide a low impedance path for transient overvoltages, such as lightning, to flow safely to earth, bypassing the sensitive equipment. Many communications facilities have large towers for mounting of antennas. Obviously these towers can be a lightning target in many parts of the country, and should be protected to the greatest degree feasible. In the case histories that follow, towers are typically grounded beyond simple Code requirements.

GOING BEYOND CODE MINIMUM – the National Electrical Code is somewhat nebulous on the requirements for low resistance grounding. The Code alludes to a desired minimum resistance to ground of 25 ohms, but does not mandate that value. The Code does mandate that certain facilities be used as grounding electrodes, if they exist, and provides rules for bonding the electrodes together. But, as for resistance, it stipulates that if 25 ohms is not achieved, an additional electrode should be installed and connected. There is no requirement for testing the resultant system, no protocol for how to test the system, or how often to repeat the testing. A more important document for power quality considerations is the IEEE Emerald Book, formally known as “IEEE Recommended Practice for Powering and Grounding Sensitive Electronic Equipment.” It has been pointed out that simply installing enhanced electrical systems and better grounding systems will prevent (or cure) many power quality problems.

GROUNDING AT A RADIO STATION – KROA is a 100 kW FM station in Doniphan, Neb., located adjacent to the Platte River. Its 500-foot antenna tower (shown in the photo to the right) is a perfect lightning rod, attracting numerous strikes in a typical summer. One such occasion a couple of years ago resulted in lightning following the coax right into the transmitter room, where it damaged several pieces of expensive equipment, and took KROA off-the-air for several weeks. Close examination by the outside professional revealed (among other things) that the primary grounding electrode exhibited 29 ohms to ground, despite a 5-foot deep water table. A new grounding installation was constructed consisting of a 40-foot deep copper-plated ground rod driven near the main service entrance; 250-kcmil copper conductor was used to connect to the ground bus, using corrosion-resistant bronze connectors and three 50-foot copper-plated electrodes were driven in a triangular pattern surrounding the antenna tower, resulting in a resistance to ground of under 3 ohms. Despite many lightning strikes since the installation described, there has been no equipment damage, nor down time since 1997.



RETROFIT OF AN OMAHA TV STATION – KPTM-TV occupies a studio facility in downtown Omaha, Neb. Trouble started when a 365-foot tower was built adjacent to the studios to transmit the signals to their main transmitter 10 miles away (see photo below – this tower is directly adjacent to another, seen at left). Lightning events caused about \$40,000 worth of equipment damage per event, plus costly downtime. Upon examination by a professional, several key retrofits were instigated that completely (as of this writing) eliminated the damage problem despite continuing lightning strikes.

First, 100-ft deep copper-clad grounding rods, one for each tower, were installed then firmly each was bonded to the towers with 250-kcmil stranded copper. Why so deep? Because the region's groundwater has high resistivity because of its low dissolved mineral content. The grounding electrodes were driven using equipment capable of measuring ground resistance as a function of depth. Final depth was selected as the point where resistance dropped below two ohms. Next, each tower was surrounded with a buried 250-kcmil bare copper ring ground. More copper bonded the rings to the tower's steel structure, to the deep electrodes and to each other. In addition, 250-kcmil pigtailed were run from the rings to the station's satellite dish antennas, the transmitter room and into the studio building. That put the entire facility at the same ground potential, eliminating ground-loop currents at their source.

Mr. Brender will present this paper on Wednesday, April 13, 2011 starting at 2:00 p.m. in room S226 of the Las Vegas Convention Center. It will also be included in its entirety in the *2011 NAB Broadcast Engineering Conference Proceedings*, on sale at the 2011 NAB Show Store and available on-line (after the Show) from the NAB Store (www.nabstore.com). Other papers being presented during this session include the following:

- *Cellular Wireless as a Video Streaming Transport: Making the "One-man-news-crew" a Reality for ENG Applications*, Dr. Cahit C. Akin, CEO, Mushroom Networks, Inc.
- *Keeping the Lights On – Business Continuity Planning for the 21st Century*, Keith Graham, director, solutions development, AZCAR USA, Inc.
- *Proactive Transmitter Service and Support Strategies*, Kevin Rodgers, director, customer service, Nautel
- *Master FM Antenna at the Empire State Building*, Joe Giardina, CTO/CEO, DSI RF Systems
- *Implementation of N+1 Technology for Improved Cost Efficiency While Maintaining Service Integrity*, Wendell Lonergan, sales manager, Middle East, Nautel

For additional conference information visit the NAB Show Web page at www.nabshow.com.



IEEE Broadcast Technology Society Issues Call for Papers

A Call for Papers has been issued for the 2011 IEEE Broadcast Symposium, to be held October 19-21, 2011, in Alexandria, Va. The Symposium Committee seeks timely and relevant technical papers relating to all aspects of broadcast technology, in particular on the following topics:



- Digital radio and television systems: terrestrial, cable, satellite, Internet, wireless
- Mobile DTV systems (all aspects, both transmission and reception)
- Technical issues associated with the termination of analog television broadcasting
- Transmission, propagation, reception, re-distribution of broadcast signals
- AM, FM, and TV transmitter and antenna systems
- Tests and measurements
- Cable and satellite interconnection with terrestrial broadcasters
- Transport stream issues – ancillary services
- Unlicensed device operation in TV white spaces

ADVERTISEMENTS




[Official NAB Privacy Policy](#)

© 2011 [National Association of Broadcasters](#) 1771 N Street, NW, Washington DC 20036

- Advanced technologies and systems for emerging broadcasting applications
- DTV & IBOC reception issues and new technologies
- ATSC and other broadcast standards developments
- Broadcast spectrum issues – re-packing, sharing

The submission deadline for abstracts is May 1, 2011. There is additional information on the [Symposium](#) on the [IEEE Broadcast Technology Society](#) website.

NAB Engineering Handbook
"A big thumper of an engineering resource...written by a list of veritable engineering all-stars."
- *Radio World Online*



NAB STORE
Publications • Research

BUY NOW!

INTRODUCING

AmWINS

PROGRAM UNDERWRITERS

An AmIBG Group Company